

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 3208

Dated: 25/3/25

It is certified that an inspection team headed by Dr. Manoj Kandpal

(Name of Officers with designation) from Nagar Nigam Haldwani PHED

inspected the Nirmala Convent Sr. Sec. School Kathgodam

(Name & Address of the school) on 25/03/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. SDLWQTMW...U.T.S.-NCS-29 dated 21/10/2024

of Sub-Divisional Water Quality Testing and Monitoring Lab, Haldwani, Nainital (PHED Lab) certified that the

Nirmala Convent Sr. Sec. School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 25/03/2025 to 24/03/2026

Signature with Seal: [Signature]

Name: [Signature]

Designation: [Signature]

Name & Address of the Office / Department : [Signature]

To Nirmala Convent Sr. Sec. School

Haldwani, Nainital

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Attested

[Signature]

Principal

Nirmala Convent Sr. Sec. School

KATHGODAM P.O.

Nainital Distt (U.K.)

Pin- 263126



"NABL Recognized

Sub Divisional Water Quality Testing and Monitoring Laboratory, Haldwani
Government Drinking Water Testing Laboratory"

Ph (O): 05946 – 220776, E-mail: eehal-ujs-uk@nic.in

Test Report ID: 29/UJS/SDLWQTML/2024-25


Dated: 03/10/2024

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	Nirmala Convent Sr.Sec.School Kathgodam-263126		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking-Water	Sample Description	One Water Sample collected from Nirmala Convent Sr.Sec.School Kathgodam.
Reference Sample Identification:	SDLWQTML/UJS/-NCS-29		Date of Start of Analysis: 01/10/2024 Date of End of Analysis: 02/10/2024
Date and Time of Sample Received: 01/10/24&11:10AM	Sample Collected by:	Customer	


SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit(BIS) in the Absence of alternative source	Std. Test Method
1	pH	8.01	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2017
2	Total Dissolved Solids (TDS), mg/L	166	500	2000	IS 3025 Pt-16-2017
3	Turbidity, NTU	0.66	1	5	IS 3025 Pt-10-2017
4	Total Alkalinity (as CaCO ₃), mg/L	114	200	600	IS 3025 Pt-23: 2019
5	Total Hardness (as CaCO ₃), mg/L	102	200	600	IS 3025 Pt-21: 2002
6	Chloride, mg/l	4.4	250	1000	IS 3025 Pt-32 : 2019
7	Calcium (as Ca), mg/L	25.6	75	200	IS 3025 Pt-40 : 2019
8	Magnesium (as Mg), mg/L	9.2	30	100	APHA 23rd Ed.-3500-MgB: 2017
9	Colour, Hazen	5	5	15	IS 3025 Pt-04 : 2021
10	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05 : 2018


(Chemist)


Manager

Nirmala Convent Sr. Sec. School
Kathgodam P.O.
Nainital Distt. (U.K.) Pin-263126


Principal
Nirmala Convent Sr. Sec. Schoc
KATHGODAM P.O.
Nainital Distt (U.K.)
Pin- 263126


(Technical Manager)
TECHNICAL MANAGER
Sub- Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS- Haldwani (Nainital)

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate. unless otherwise agreed with customer.



Sub Divisional water Quality Testing and Monitoring Laboratory, Haldwani
Government Drinking Water Testing Laboratory

Ph (O): 05946 – 220776, E-mail: eehal-ujs-uk@nic.in


Test Report ID: 29A/UJS/SDLWQTML/2024-25


Dated: 03/10/2024


WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	Nirmala Convent Sr.Sec.School Kathgodam-263126		
Product Description	Drinking-Water	Sample Description	One Water Sample collected from Nirmala Convent Sr.Sec.School Kathgodam.
Reference Sample Identification:	SDLWQTML/UJS/-NCS-29		Date of Start of Analysis: 01/10/2024 Date of End of Analysis: 02/10/2024
Date and Time of Sample Received: 01/10/24&11:10AM	Sample Collected by:	Customer	

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS) as per IS 10500:2012	Permissible Limit (BIS) in the Absence of alternative source IS 10500:2012	Std. Test Method
BACTERIOLOGICAL PARAMETERS					
1.	<i>Total Coliform, MPN/100ML</i>	ABSENT	Absent	Absent	APHA 23 rd ED-9223-D
2.	<i>E.coli, MPN/100ML</i>	ABSENT	Absent	Absent	APHA 23 rd ED-9223-D


(Chemist)


(Technical Manager)
TECHNICAL MANAGER
Sub- Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS- Haldwani (Nainital)


Manager
Nirmala Convent Sr. Sec. School
Kathgodam P.O.
Nainital Distt. (U.K.) Pin-263126


Principal
Nirmala Convent Sr. Sec. School
KATHGODAM P.O.
Nainital Distt (U.K.)
Pin-263126

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.